



IEA Technology Collaboration Programme

International Energy Agency

Technology Collaboration Programme on

Energy Storage (ES TCP)

**Storage for renewables and flexibility
through standardized use of building mass**

Questionnaire: SIMULATION

Version: 13th of June, 2024

Contact:

Daniel Muschick
daniel.muschick@best-research.eu

Dear madam or sir,

thank you for taking the time to fill out this questionnaire! In order to provide a good overview of available **simulation tools** / simulation **models** dealing with **thermally activated building components**, we require your knowledge and expertise. Please use this opportunity to make your work known or provide useful information for other interested parties about tools or models you use or have experience with.

If you give us your personal information, we can keep in touch and maybe consider you as a co-author in possible publications or reports.

Personal Information (optional)	
Name: (Family name, given name):	Kersken, Matthias
E-Mail:	Matthias.kersken@ibp.fraunhofer.de
Contact	☒ I am available for follow-up questions

Company / Institution	
Name:	Fraunhofer-Institute for Building Physics IBP
Country:	Germany
Type:	☐ University / Education ☒ Research Institution ☐ Company using simulation software ☐ Company developing simulation software

Please give feedback on categories of simulation software you are developing and / or using.

We distinguish between two different categories of mathematical models, depending on their intended usage: **Detailed simulation models** should reproduce measurements as precisely as possible and are intended for planning, e.g., in construction. **Prediction models** have reduced complexity and can be used for very fast simulations or even within optimization problems, e.g., in control tasks, to predict how changes in the operation influence the temperature and comfort of residents.

Please provide information on one or both of the simulation types, depending on your professional experience.

Note that your responses will be made available to the task participants and may be used in the preparation of official reports that will be made publicly available.

Please send the questionnaire to daniel.muschick@best-research.eu once you have filled it out.
Thank you!

Detailed Simulation Models

Detailed simulation models are used to calculate the behaviour of systems in reality (temperature propagation, heat bridges, constructive stability, humidity, dew points, ...) as precisely as possible. They may also be used to test control strategies, which may depend on simplified prediction models, before implementing them. The parametrization of the models is done by specifying physical and geometric properties, i.e., It is not necessary to have real measurement data to setup a simulation.

The focus is on simulation algorithms and tools either with a special focus on activated building components or which at least can handle them well.

Detailed simulation models are typically part of a software package (TRNSYS, Modelica) or are a dedicated software tool themselves (IDA ICE, ...). If your input is more about the method than the tool, please feel free to add information in the “Additional information” field.

If you have experience / information on multiple tools, please feel free to copy the table.

Detailed Simulation Tool / Model		
Name:	TRNSYS	
Homepage:	https://trnsys.de/	
Relationship to you:	☐ I / my company are developing this software ☐ I / my company are using this software on a daily basis ☒ I / my company are using this software sporadically ☐ Other:	
License:	☐ Not publicly available; developed in-house, e.g., in research projects ☒ Commercial license ☐ Free software ☐ Open source ☐ Other:	
Type:	☒ Stand-alone software ☐ Library / Plugin for: ☐ Other:	
Co-Simulation Interfaces:	☐ None ☒ FMI / FMU ☐ Custom (e.g., call to DLL) ☐ Other: Python, Mathlab, Excel, EES, Contam, ESPr, Mathis	
Consideration of TABS:	☒ Ceiling ☒ Floor ☒ Wall ☒ Other: Thermal masses inside a room	☒ Concrete ☒ Brick ☒ Wood ☒ Other materials: can be defined freely

Method to consider TABS¹:	☐ Ordinary differential equations (ODE) ☐ Partial differential equations (PDE) ☐ Finite Element Method (FEM) ☒ Other: Stationary solution of ODE
Scope:	☐ Component ☒ Room ☒ Building ☐ City (quarter) ☐ Other:
Main application:	<i>Analysis of building service system performance together with thermal indoor comfort</i>
Integration of control:	☐ None (e.g., steady state calculations only) ☒ Controllers defined in model ☒ External control possible with co-simulation interface ☐ Other:
USP: (unique selling point)	<i>Many physical models integrated, free definition of control strategies</i>
Alternatives:	<i>IDA-ICE, WUFI-Plus</i>
Publications on method:	<i>TRNSYS user manual</i>
Publications on applications:	<i>TRNSYS user manual</i>
Additional Information:	

Open Challenges for Detailed Simulation Models

MPC logic is difficult to integrate.

¹ How are thermally activated building components represented in the simulation? If, for example, the entire slab is considered as one block (1D model), this would correspond to an ODE. If piping space can be considered, it could be either PDE or FEM

Prediction Models

Prediction models are simplified models that focus on the input/output relationship of thermal zones or buildings, i.e., how different operating strategies will affect the temperature and comfort experienced by the residents. They are directly used as models in optimization problems or for quick evaluations of scenarios. They are often resistor/capacitor (RC) equivalent models of a certain order, (linear) state-space models or data-driven models based on Machine Learning / Artificial Intelligence.

Here, the focus is less on the tool / software, and more on the **method**.

Specifically, the problem of **parametrization** (based on measurements or derived from more detailed models), and the **mathematical complexity** (linear, mixed integer, non-linear) – and thus the ease of integration into optimization problems – are of interest here.

Prediction Model	
Name:	<i>Efficiency Signatur Method (EfSM)</i>
Homepage:	https://astra-cloud.com/efsm/
Relationship to you:	☒ I / my company are developing this model ☐ I / my company are using this model on a daily basis ☐ I / my company are using this model sporadically ☐ Other:
License:	☒ Not publicly available; developed in-house, e.g., in research projects ☐ Commercial license ☒ Free software – for measurement data compensation ☐ Open source
Type:	☒ Mathematical model only ☐ Stand-alone software ☐ Library / Plugin for: ☐ Other:
Method / Complexity:	☐ State space / Ordinary Differential Equation (nonlinear) ☐ State space / Ordinary Differential Equation (linear), e.g., RC model ☐ Neural network ☒ Other: Finite response filter
Scope:	☐ Individual room temperature ☒ Multiple rooms / entire building ☐ Multiple buildings ☐ Other:
Main application:	<i>Long term storage management (1-2 weeks) -> heat demand prediction</i>

Usage²:	☐ Simulation studies ☒ Real-world implementation and control (Windheizung 2.0) ☐ Other:
Consideration of comfort³:	☒ Indoor air temperature (by set temperatures, no prediction) ☐ Surface temperatures ☐ Air draft ☐ Humidity ☐ Other:
USP: <i>(unique selling point)</i>	<i>Very few training data required, nearly no calculation cost.</i>
Alternatives:	<i>other methods of time series analysis. Instead of a FIR Xtreme Gradient Boost models have performed good and fast</i>
Thermally activated components:	☐ Implicitly considered (depending on parametrization) ☒ Explicitly considered ☐ Other:
Phenomena considered:	☒ Ambient temperature ☒ Solar irradiation ☐ Internal gains (preconfigured) ☐ Internal gains (automatically detected) ☐ Shading ☐ Air ventilation ☐ Interaction (heat / air exchange) between the rooms ☐ Interaction with the energy hub (heat flows, feed temperature, ...) ☒ Other: Auxiliary heat supply in case TABS has run cold

² How has the model/the method been used / what is it intended for?

Simulation studies can give an indication, e.g., on the benefits of using TABS or intelligent controllers. The models they use for control/optimization, however, need not represent a real building, but perhaps only a simplified version of a more detailed model used for validation of the controller. The parametrization and estimation of internal gains etc. are, therefore, possibly simpler.

Real-world implementation and control, on the other hand, requires either a robust control algorithm or a very good match between the model parameters and reality.

³ Good control algorithms should not only consider temperature, but also other comfort parameters.

Parametrization⁴:	☐ Manual ☐ Derived from detailed simulation model: <i>please indicate possible sources / file formats</i> ☐ Derived from archetypes ☒ Automatic via historic measurements (controlled operation) ☐ Automatic via historic measurements (specific experiments) ☒ Automatic parameter update (online)
Publications on method:	<i>tbd</i>
Publications on applications:	https://astra-cloud.com/efsm/
Additional Information:	

Open Challenges for Prediction Models

Good prediction on multi day average, hourly performance is work to be done

Thank you for completing the questionnaire! Kindly send back the filled-out form to daniel.muschick@best-research.eu.

⁴ Every model depends on its parameters. Please indicate how they are determined in this model/method.

Manual: The user has to choose the parameters by hand, e.g. by running multiple simulations and adjusting the parameters.

Derived from detailed simulation model: A detailed (building) simulation model is used to parametrize a more simplified model. Example: BRCM Toolbox of ETH Zurich.

Derived from archetypes: The parameters are chosen from a set of pre-defined parameters. This is more suitable for performing simulation studies, but probably not enough for the control of an actual building.

Automatic via historic measurements: The parameters are estimated from historic measurements, e.g., using a least-squares based algorithm or any data-driven method. “Controlled operation” means that the algorithm can cope with measurements taken in an already controlled environment, meaning that the room temperatures stay close to the setpoints and little information on the effect of heating/cooling is available. “Specific experiments” means that special heat-up / cooldown experiments need to be performed in order to obtain trustworthy parameter estimates.

Automatic parameter update: The parameters are not only estimated once, but continuously adapted based on new measurements. This requires methods ensuring that the parameters do not take on meaningless values.