



IEA Technology Collaboration Programme

International Energy Agency

Technology Collaboration Programme on

Energy Storage (ES TCP)

**Storage for renewables and flexibility
through standardized use of building mass**

Questionnaire: SIMULATION

Version: 19th of February, 2024

Contact:

Daniel Muschick
daniel.muschick@best-research.eu

Dear madam or sir,

thank you for taking the time to fill out this questionnaire! In order to provide a good overview of available **simulation tools** / simulation **models** dealing with **thermally activated building components**, we require your knowledge and expertise. Please use this opportunity to make your work known or provide useful information for other interested parties about tools or models you use or have experience with.

If you give us your personal information, we can keep in touch and maybe consider you as a co-author in possible publications or reports.

Personal Information (optional)	
Name: (Family name, given name):	Garay-Martinez, Roberto
E-Mail:	roberto.garay@deusto.es
Contact	☒ I am available for follow-up questions

Company / Institution	
Name:	University of Deusto
Country:	Spain
Type:	☒ University / Education ☐ Research Institution ☐ Company using simulation software ☐ Company developing simulation software

Please give feedback on categories of simulation software you are developing and / or using.

We distinguish between two different categories of mathematical models, depending on their intended usage: *Detailed* simulation models should reproduce measurements as precisely as possible and are intended for planning, e.g., in construction. *Simplified* models have reduced complexity and can be used for very fast simulations or even within optimization problems, e.g., in control tasks.

Detailed Simulation

Detailed simulation models are used to predict the behaviour of systems in reality (temperature propagation, heat bridges, constructive stability, humidity, dew points, ...) as precisely as possible. They may also be used to test control strategies before implementing them.

The focus is on simulation algorithms and tools either with a special focus on activated building components or which at least can handle them well.

Detailed simulation models are typically part of a software package (TRNSYS, Modelica) or are a dedicated software tool themselves (IDA ICE, ...). If your input is more about the method than the tool, please feel free to add information in the "Additional information" field.

If you have experience / information on multiple tools, please feel free to copy the table.

Detailed Simulation Tool / Model		
Name:	TRNSYS	
Homepage:		
Relationship to you:	☐ I / my company are developing this software ☐ I / my company are using this software on a daily basis ☒ I / my company are using this software sporadically ☐ Other:	
License:	☐ Not publicly available; developed in-house, e.g., in research projects ☒ Commercial license ☐ Free software ☐ Open source ☐ Other:	
Type:	☒ Stand-alone software ☐ Library / Plugin for: ☐ Other:	
Co-Simulation Interfaces:	☒ None ☐ FMI / FMU ☐ Custom (e.g., call to DLL) ☐ Other:	
Consideration of TABS:	☒ Components ☒ Ceiling ☒ Wall ☐ Other:	☐ Concrete ☐ Brick ☐ Wood ☐ Other materials:
Method to consider TABS¹:	☐ Ordinary differential equations (ODE) ☐ Partial differential equations (PDE) ☒ Finite Element Method ☐ Other:	
Scope:	☒ Component ☒ Room ☒ Building ☐ City (quarter) ☐ Other:	
Main application:	<i>Building energy simulation, integration of renewable energy systems, advanced control systems</i>	
USP: (unique selling point)	<i>What makes this tool better/different from other simulation tools</i> N/S	
Alternatives:	<i>If you know about similar solutions, please denote them here. Ideally, copy this table and fill it out for the alternative as well.</i>	
Speed:	☐ Seconds ☒ Minutes	

¹ How are thermally activated building components represented in the simulation? If, for example, the entire slab is considered as one block (1D model), this would correspond to an ODE. If piping space can be considered, it could be either PDE or FEM

(approximate time for simulating one day)	☐ Hours ☐ Other:
Publications on method:	<i>E.g., own publications on the methodology; review papers</i> <i>For commercial products: Link to publicly available information</i>
Publications on applications:	<i>E.g., simulation studies performed with this tool</i>
Additional Information:	<i>Please provide any information you consider of interest, e.g., provide details only asked of simplified simulation models</i>

Open Challenges for Detailed Simulation Models

Please indicate open challenges for detailed simulation models and tools, esp. regarding the correct representation and integration of thermally activated components.

Simplified Simulation Models / Prediction Models

Simplified simulation models are often resistor/capacitor (RC) equivalent models of a certain order, (linear) state-space models or data-driven models based on Machine Learning / Artificial Intelligence. They are directly used as prediction models in optimization problems or for quick evaluations of scenarios.

Here, the focus is probably less on the tool / software, and more on the **method**.

Specifically, the problem of **parametrization** (based on measurements or derived from more detailed models), the **mathematical complexity** (linear, mixed integer, non-linear) – and thus the ease of integration into optimization problems – are of interest here.

Simplified Simulation Model	
Name:	<i>Self-developed models</i>
Homepage:	<i>(if applicable)</i>
Relationship to you:	☒ I / my company are developing this model ☐ I / my company are using this model on a daily basis ☐ I / my company are using this model sporadically ☐ Other:
License:	☒ Not publicly available; developed in-house, e.g., in research projects ☐ Commercial license ☐ Free software ☐ Open source
Type:	☒ Mathematical model only ☒ Stand-alone software ☐ Library / Plugin for: ☐ Other:

Method / Complexity:	☐ State space / Ordinary Differential Equation (nonlinear) ☒ State space / Ordinary Differential Equation (linear), e.g., RC model ☐ Neural network ☐ Other:
Scope:	☒ Individual room temperature ☒ Multiple rooms / entire building ☐ Multiple buildings ☐ Other:
Main application:	<i>Fast simulations to be coupled with controlled in MPC contexts</i>
Usage²:	☒ Simulation studies ☒ Real-world implementation and control ☐ Other:
USP: (unique selling point)	<i>What makes this method better/different from other models</i> <i>Fast, standalone and integrable with third-party software through neutral interfaces.</i>
Thermally activated components:	☒ Implicitly considered (depending on parametrization) ☐ Explicitly considered ☐ Other:
Alternatives:	<i>There are many similar models with different approaches</i>
Phenomena considered:	☒ Ambient temperature ☒ Solar irradiation ☒ Internal gains (preconfigured) ☐ Internal gains (automatically detected) ☐ Shading ☒ Air circulation ☒ Interaction between rooms ☐ Interaction with the energy hub (heat flows, feed temperature,...) ☐ Other:
Parametrization³:	☒ Manual

² How has the model/the method been used / what is it intended for?

Simulation studies can give an indication, e.g., on the benefits of using TABS or intelligent controllers. The models they use for control/optimization, however, need not represent a real building, but perhaps only a simplified version of a more detailed model used for validation of the controller. The parametrization and estimation of internal gains etc. are, therefore, possibly simpler.

Real-world implementation and control, on the other hand, requires either a robust control algorithm or a very good match between the model parameters and reality.

³ Every model depends on its parameters. Please indicate how they are determined in this model/method.

Manual: The user has to choose the parameters by hand, e.g. by running multiple simulations and adjusting the parameters.

Derived from detailed simulation model: A detailed (building) simulation model is used to parametrize a more simplified model. Example: BRCM Toolbox of ETH Zurich.

Derived from archetypes: The parameters are chosen from a set of pre-defined parameters. This is more suitable for performing simulation studies, but probably not enough for the control of an actual building.

Automatic via historic measurements: The parameters are estimated from historic measurements, e.g., using a

	☐ Derived from detailed simulation model: <i>please indicate possible sources / file formats</i> ☐ Derived from archetypes ☐ Automatic via historic measurements (controlled operation) ☐ Automatic via historic measurements (specific experiments) ☐ Automatic parameter update (online)
Publications on method:	<i>Iñigo Lopez-Villamor, Olaia Eguiarte, Beñat Arregi, Roberto Garay-Martinez, Antonio Garrido-Marijuan, Time of the week AutoRegressive eXogenous (TOW-ARX) model to predict thermal consumption in a large commercial mall, Energy Conversion and Management: X, 2024, https://doi.org/10.1016/j.ecmx.2024.100777</i> Mikel Lumbreras, Gonzalo Diarce, Koldobika Martin, Roberto Garay-Martinez, Beñat Arregi, Unsupervised recognition and prediction of daily patterns in heating loads in buildings, Journal of Building Engineering, 2023, https://doi.org/10.1016/j.jobee.2022.105732 Mikel Lumbreras, Roberto Garay-Martinez, Beñat Arregi, Koldobika Martin-Escudero, Gonzalo Diarce, Margus Raud, Indrek Hagu, Data driven model for heat load prediction in buildings connected to District Heating by using smart heat meters, Energy, 2022, https://doi.org/10.1016/j.energy.2021.122318 Markel Eguizabal, Roberto Garay-Martinez, Iván Flores-Abascal, Simplified model for the short-term forecasting of heat loads in buildings, Energy Reports, 2022, https://doi.org/10.1016/j.egy.2022.10.224 I. G. de Eulate, R. Garay-Marinez, B. A. Goikolea, O. Eguiarte and A. M. Macarulla, «Simplified Geometric Processing of Solar Radiation for Improved Data-Driven Modelling of Short-Term Energy & Comfort Performance in Buildings,» 2024 9th International Conference on Smart and Sustainable Technologies (SpliTech), Bol and Split, Croatia, 2024, https://doi.org/10.23919/SpliTech61897.2024.10612489, https://zenodo.org/records/13827593
Publications on applications:	<i>Ruben Mulero, Roberto Garay-Martinez, Beñat Arregi, Iñigo Mendiadua, Integrated HVAC and building simulation, 2023 https://github.com/rubenmulero/hvac_house_simulation</i>

least-squares based algorithm or any data-driven method. “Controlled operation” means that the algorithm can cope with measurements taken in an already controlled environment, meaning that the room temperatures stay close to the setpoints and little information on the effect of heating/cooling is available. “Specific experiments” means that special heat-up / cooldown experiments need to be performed in order to obtain trustworthy parameter estimates.

Automatic parameter update: The parameters are not only estimated once, but continuously adapted based on new measurements. This requires methods ensuring that the parameters do not take on meaningless values.

Additional Information:	<i>Please provide any information you consider of interest, e.g., provide details only asked of simplified simulation models</i>
------------------------------------	--

Open Challenges for Simplified Simulation Models
<i>Please indicate open challenges for simplified simulation models and tools, esp. regarding the correct representation and integration of thermally activated components.</i>

Thank you for completing the questionnaire! Kindly send back the filled-out form to daniel.muschick@best-research.eu.