

The Xylem HT-BTES in Emmaboda, Sweden

IEA HPT – Task 45 Webinar 2, Dec 16, 2025

Presented by

Olof Andersson, Geostrata HB

olle.geothermal@hotmail.com


Xylem Emmaboda

- Manufacturer of pumps
- 1100 employed
- 110 000 m² in-door area
- Foundry and workshops
- Large user of electricity



Why a BTES system?


- Improved use of waste heat to replace district heating
- Minimized usage of cooling towers
- Reached by using BTES for seasonal storage




Principal flow of thermal energy

COOLING NEEDS




Melting ovens




WASTE HEAT CAPTURE



Processes






Ventilation




INTERNAL GRID FOR HEAT


WASTE HEAT USAGE



Project stages and their main contents




Basis for design of BTES capacity



Model simulation (DTS)

ASUMPTIONS

- Stored heat, 3 200 MWh/a
- Heat losses, 30%
- Fluid, water
- Flow rate, 25 l/s
- Working temp, 60/40°C




Coaxial borehole heat exchanger. New design

- Dual pipes
- Insulated by standing water
- Threaded in 10 m lengths
- Allow reversed circulation
- Borehole resistance,
0,02 mK/W



Drilling method


DTH with compressed air



Borehole design

- Number, 140
- Depth, 150 m
- Diameter, 115 mm
- Spacing, 4,5 m
- Surface, 2400 m²
- Volume, 300 000 m³
- Thermal conductivity, 2,9 W/m,K

Horizontal pipe system





Insulated by foam glass

- Light and easy to handle
- Made of recycled glass
- Thermal conductivity, 0,4 W/m,K




Monitoring phase 1 (2011-2015)

- Stored heat, 12 GWh
Recovered, 280 MWh (8%)
- Working temp 60/40 not in sight
- Extraction heat pump suggested



After two more years

- Stored temp. levels out around 45°C
- The system still works for dumping heat (cooling)
- Heat recovery 12% is too low
- Extraction heat pump decided



Heat pump system installed 2018

- Eight units NIBE F1345-60
- Nominal capacity 480 kW
- Actual capacity 800 kW
(+25/20°C as heat source)




Second phase of monitoring 2018-2021

Part of IEA HPT Annex 52


Monitoring of long-term
performance factors (SPF)
mainly based on

- Thermal energy turnover
- Electricity used
- Thermal behavior in general



COP injection/extraction (SPF0)


Delta T depended (varies between 10-15°C)





COP heat pump system (SPF1)

—


“Cold side” circulation
pumps included



BTES Working temperature down to 20/40°C



Before and after HP- installation



Economics (compared to DH)

Initial investment 2010-12

- Investment: 13,5 Mill. SEK
- **Expected heat: 2 200 MWh/a**
- Annual saving: 1,3 Mill. SEK
- Straight payback: 10 years

Additional investment 2018

- Investment: 3,0 Mill. SEK
- Produced heat: 2 200 MWh/a
- Annual saving: 1,6 Mill. SEK
- Straight payback: < 2 years

If constructed today (with HP:s)

- Investment: Approx. 22 Mill. SEK
- Produced heat: 2 400 MWh/a
- Annual saving: 2,5 Mill. SEK
- Straight payback: <10 years

Heat pumps rescued Xylem's heat storage facility in Emmaboda, Sweden

Conclusion

Thanks for your attention!



OLOF ANDERSSON



NIKLAS HÄKANSSON



LEIF RYDELL